



Build Green, Live Green!
CIN:U45200BR2008SGC013513

बिहार राज्य भवन निर्माण निगम लिमिटेड

An ISO 9001:2008, 14001:2004 & OHSAS 18001:2007 Certified Company

बिहार सरकार का एक उपक्रम

वेबसाइट: www.bsbcccl.bih.nic.in

BIHAR STATE BUILDING CONSTRUCTION CORPORATION LTD.

An ISO 9001:2008, 14001:2004 & OHSAS 18001:2007 Certified Company

A Government of Bihar Undertaking

Website: www.bsbcccl.bih.nic.in


Ref.No.:- B.S.B.C.C.L - G.M (H.Q.) 677/2014

1968

Dated: 27/06/15

The query raised for the above work is complied as under.

1. The addressible fire alarm shall be of ATEIS/Honeywell/L&T or Similar Superior make.
2. Successful Vendor will submit the GFC drawing after finalisation of Tender for approval. During detailed Engineering and Co-rodination the final Qnty, will be arrived for all the items not only detectors, However the Qnty has been taken into consideration as per NBC 2005 and CPWD specification. The Final qnty may be more or less but it will be within the daviation limit.
3. As per fire by laws all the area shall be covered under fire survilance. However the authority is free to take decision for such query.
4. The qnty mentioed is Estimated for the work. The Qnty actually executed will be measured and will be paid accordingly. Payment will not based on the Qnty mentioned in the BOQ but will be on the Qnty executed, So no relevance in asking the questation for Qnty. The agency has to quote the rates only for the items.
5. The pump room as a part of major civil work can not be specified in the BOQ. It shall be executed as per the drawing by the Civil contactor/Building contractor. The provision of fire bucket/Extinguisher etc will be under the scope of External Electrification under safety equipmets.
6. Selected venders have to submit the soft drawing of fire layout and fixtures to BSBCCCL and after approval of the soft drawing by competent authority work will proceed.


Sureshwar Sharma
G.M. (H.Q.),
BSBCCL, Patna

